



June 4, 2018

RM of Keys
Box 899
Canora, SK
S0A 0L0

Dear Waterworks Owner/Operator:

RE: Rescinding - Precautionary Drinking Water Advisory - Hamlet of Crystal Lake

The Water Security Agency is advising that the “**Precautionary Drinking Water Advisory**” (PDWA) issued by the Water Security Agency for the Hamlet of Crystal Lake potable water system be rescinded, as of 13:00hrs Monday, June 4, 2018.

The rescinding of the PDWA was based upon information provided by your community, which included:

- The distribution system has been pressurized, and flushed, according to applicable standards.
- The receipt of two (2) consecutive sets of two (2) bacteriological samples collected one day apart that are negative for bacteriological growth in the final treated potable water being supplied throughout the distribution system mentioned above.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Hamlet of Crystal Lake in addressing the advisory.

Thank you for your cooperation in this regard. For further information please do not hesitate to contact the undersigned at (306) 786-1424.

Sincerely,

A handwritten signature in black ink, appearing to read "Rick Sheichuk".

Rick Sheichuk
Environmental Services Section - South
Environmental and Municipal Management Services Division
Water Security Agency

CC. Greg Holovach, Water Security Agency - Environmental and Municipal Management Services Division
Gilbert Combres – Saskatchewan Health Authority